

THE SCHEDULE
FORM-A

(Form of application under Sub-Section (1) Sub-Section (2) of Section 4 of the Tamilnadu Public Buildings (Licensing) Act 1965.(Madras Act XIII of 1965) referred to in Rule 3 of the TamilNadu Public Buildings (Licensing) Rules 1996)

From

The Secretary/Correspondent
MRM International Senior Secondary School (CBSE)
S.F.No.970/1A pt, Tekkattur Village
Arimalam Panchayat Union
Thirumayam Taluk,
Pudukkottai District-622 422

To
The Competent Authority
The Thasildhar
Thirumayam

Sir

I intend to use the building/to continue to use the existing Public building not at present used as a public building, which is situated in the site of Plot or S.F.No.970/1Apt, Vellar Bridge Road , Tekkattur , in the ward or division /village/district of PUDUKKOTTAI and specified in the statement enclosed as a public building for a period of 3 years and from the 01.04.2020 to 31.03.2023

2. The year of Construction and the present approximate Cost of Construction And the purpose for which it is to be used or is being used as a Public bldgs Are also furnished in the statement accompanying this application.
3. I enclose a Chelan for Rs.1000/
4. I also enclose Certificate of Structural soundness in the prescribed form Furnished by the Engineer Shri.A.BALASUBRAMANIAN-PANEL ENGINEER GRADE-IA (Any amount), Approved by PUDUKKOTTAI District Collector thro Proceedings No.B1/44729/2005.

Signature of the owner of the bldg

Date :

Enclosures: 1. Statement
2. Original Chelan for Rs. 500/-Towards the application fee.

STATEMENT ACCOMPANYING FORM-A

1. Door Number of the Building : S.F.No.970/1Apt
2. Location (st.No.ward.No,Name of Place ie Corporation/Municipality/ Panchayat/Panchayat Union/ Contonment : Tekkattur Village
: Arimalam Panchayat Union
: Thirumayam Taluk
: Pudukkottai District—622 422
3. Year of construction : GF & FF--2011, 2014: SF-2015-16
4. App.Cost of Constn as per current rate : Rs. 1,95,00,0 00/-
5. Purpose for which this building is Being used or proposed to be used : To run an International Senior
: Secondary school (CBSE)
6. Purpose for which this bldg has Hither to been used :do.....
7. Details of Constn of the bldg (parti Culars of the foundation and specfn Of the various parts under)
 1. Foundation : RCC Footing with Mat
 2. Basement :do.....
 3. Superstructure : Bw in CM
 4. Floor & roof are to be given : Cement floor
: RCC roof
8. Period for which the License is Required : 3 years
9. Number of Persons to be Accommodated : 1000 students

Date : 20.09.2020

Signature of the Engineer

A. BALASUBRAMANIAN, B.E.,M.I.E.,
CHARTERED ENGINEER & PANEL ENGINEER GRADE - 1A
PUDUKKOTTAI DISTRICT
49, Muneeswaran Koil Street,
KARAIKUDI - 630 001. Mob : 9442237183

Certified that no addition or alteration has been made to the extg building or portion of a bldg for which this application has been made. I undertake to obtain a fresh License, incase any addition or alteration is made to the extg bldg or portion of a bldg. I also undertake to obtain a fresh License,if the purpose for which the license was granted for the use of the building or a portion of the bldg originally is changed or altered subsequently .

Signature of the owner of the Building.

FORM-B

(Form of Certificate of structural Soundness under Sub-Section (4) of the Section 4 of the Tamilnadu Public Buildings (Licensing) Act 1965 (TamilNadu Act 13 of 1965 referred to in rule 4 of the TamilNadu Public Buildings (Licensing) Rules 1966.)

I certify that I have inspected the building, mentioned in the statement and furnish below The salient technical features.


1. Foundation :

- i. Depth below Ground Level : 180 cm
- ii. Nature of Soil met with at foundation level : Medium soil
- iii. Pressure at Foundation : 24.00 T/sqm
- iv. Probable SBC of the treatment met with At foundation level. : 35.00 T/sqm

2. Superstructure :

- i. Max.stress in the most critical section of
- | | |
|----------|-----------------|
| Masonry | : 16.50 Kg/sqcm |
| Concrete | : 27.00 Kg/sqcm |
- ii. Nature of masonry and Concrete and its safe permissible stresses
- | | |
|----------|------------------|
| Masonry | : 35.00 Kg/sqcm |
| Concrete | : 150.00 Kg/sqcm |

The structural soundness of the building has been verified by me with reference to ISI Loading Standards 875 (Latest Version) and other relevant Indian Standards Code of Practice and I Declare that the Building is structurally Sound to be used as a Public Building for the purpose noted in the statement. A license may be granted for the period of 3 years from the 01.04.2020 to the 31.03.2023 inclusive of this date.



Signature of the Engineer.

A. BALASUBRAMANIAN, B.E.,M.I.E.,
CHARTERED ENGINEER & PANEL ENGINEER GRADE - 1A
PUDUKKOTTAI DISTRICT
49, Muneeswaran Koil Street,
KARAIKUDI - 630 001. Mob : 9442237183

Date : 20.09.2020

ANNEXURE TO FORM-B

(Statement to accompany the Certificate of structural soundness)

01. Location of the building : MRM International Senior Secondary
Door No, Street No and : School (CBSE)
Name of Place : S.F.No.970/1 Apt
: Tekkattur Village
: Arimalam Panchayat Union
: Thirumayam Taluk
: Pudukkottai District--622 422
02. Number, Age of the Building : One—09 years
03. Short Description of structures :
Steel/RCC framed or Load :
Bearing walls : RCC Framed
04. Purpose for which the Building is :
Certified for use : To run an International Senior
Secondary School (CBSE)
05. The Period for which the building :
Will be structurally sound : 3 years
06. Number of Persons to be :
Accommodated : 1000 students
07. Remarks : Form E & Declaration is attached

Date : 20.09.2020

Signature of the Engineer

A. BALASUBRAMANIAN, B.E., M.I.E.
CHARTERED ENGINEER & PANEL ENGINEER GRADE - 1
PUDUKKOTTAI DISTRICT
49, Muneeswaran Koil Street,
KARAIKUDI - 630 001. Mob : 944223718

FORM-C

(Form of Certificate of structural Soundness under Sub-Section (4) of the Section 4 of the Tamilnadu Public Buildings (Licensing) Act 1965 (TamilNadu Act 13 of 1965 referred to in rule 4 of the TamilNadu Public Buildings (Licensing) Rules 1966.)

I certify that I have inspected the building, mentioned in the statement and furnish below The salient technical features.

1. Foundation :

- i. Depth below Ground Level : 180 cm
- ii. Nature of Soil met with at foundation level : Medium Soil
- iii. Pressure at Foundation : 24.00 T/sqm
- v. Probable SBC of the treatment met with At foundation level. : 35.00 T/sqm

2. Superstructure :

- i. Max.stress in the most critical section of
- | | |
|----------|-----------------|
| Masonry | : 16.50 Kg/sqcm |
| Concrete | : 27.00 Kg/sqcm |
- ii. Nature of masonry and Concrete and its safe permissible stresses
- | | |
|----------|------------------|
| Masonry | : 35.00 Kg/sqcm |
| Concrete | : 150.00 Kg/sqcm |

The structural soundness of the building has been verified by me with reference to ISI Loading Standards 875 (Latest Version) and other relevant Indian Standards Code of Practice and I Declare that the Building is structurally Sound to be used as a Public Building for the purpose noted in the statement. A license may be granted for the period of 3 years from the 01.04.2020 to the 31.03.2023 inclusive of this date.

Date : 20.09.2020


Signature of the Engineer.

A. BALASUBRAMANIAN, B.E., M.I.E.,
CHARTERED ENGINEER & PANEL ENGINEER GRADE - 1A
PUDUKKOTTAI DISTRICT
49, Muneeswaran Koil Street,
KARAIKUDI - 630 001. Mob : 9442237183

STATEMENT TO ACCOMPANY THE OPINION REGARDING STRUCTURAL SOUNDNESS

01. Location of the building : MRM International Senior Secondary
Door No, Street No and : School (CBSE)
Name of Place : S.F.No.970/1Apt
: Tekkattur Village
: Arimalam Panchayat Union
: Thirumayam Taluk,
: Pudukkottai District-622 422
02. Number, Age of the Building : One--09 years
03. Number of Stories : GF to SF
04. Short Description of structures.
Steel/RCC framed or Load
Bearing walls : RCC Framed
05. Purpose for which the Building is
Certified for use : To run an International Senior
: Secondary School
06. The Period for which the building
Will be structurally sound : 3 years
07. Number of Persons to be
Accommodated : 1000 students
08. Remarks : Form E & Declaration is attached

Date : 20.09.2020



Signature of the Engineer

A. BALASUBRAMANIAN, B.E., M.I.E.,
CHARTERED ENGINEER & PANEL ENGINEER GRADE - 1A
PUDUKKOTTAI DISTRICT
49, Muneeswaran Koil Street,
KARAIKUDI - 630 001. Mob : 9442237183

KARAIKUDI - 630 001. Mob : 9442237183
49, Muneeswaran Koil Street,
PUDUKKOTTAI DISTRICT
CHARTERED ENGINEER & PANEL ENGINEER GRADE - 1A
A. BALASUBRAMANIAN, B.E., M.I.E.

FORM -E

{(Form of report to be made to the competent authority by inspecting authorities or officers Appointed under other Acts Under section 28 of the Tamilnadu Public Buildings (Licensing) Act 1965 (Madras Act XIII of 1965) referred to in rule 7 of the Tamilnadu Public Buildings (Licensing) Rules, 1966)}

1. Name and designation of inspecting authority or : A.Balasubramanian.,B.E., M.I.E,M.E.C.I
Officer appointed or having jurisdiction under : Panel Engineer Grade-1A (any amount)
Any other Act or Law : Pudukkottai District
2. Location of the Building inspected (Door No. : **MRM INTERNATIONAL SENIOR**
Street Number, Name of Place ie Municipal : **SECONDARY SCHOOL (CBSE)**
Corporation/Municipality/Panchayat or : S.F.No.970/1Apt, Tekkattur Village,
Panchayat Union/Township/Cantonment) : Arimalam Panchayat Union
: Thirumayam Taluk
: Pudukkottai District
3. Date of Inspection : 13.09.2020
: Date of issue of Certificate
: 20.09.2020
4. Purpose for which the building is used : To run an International Senior
: Secondary School
5. Nature of defects noticed : Nil
6. Suggestions for rectifying defects : Given in the SSC & Declaration
7. If in a dangerous condition, immediate :
Steps recommended to be taken : Nil

Date : 20.09.2020

Signature of the inspecting authority or
Officer appointed or having jurisdiction

Copy to

1. P.A. to the Collector- Pudukkottai
2. R.D.O.—Pudukkottai.

A. BALASUBRAMANIAN, B.E., M.I.E.,
CHARTERED ENGINEER & PANEL ENGINEER GRADE - 1A
PUDUKKOTTAI DISTRICT
49, Muneeswaran Koil Street,
KARAIKUDI - 630 001. Mob : 9442237183

DECLARATION BY THE PANEL ENGINEER-1A (Any amount)

MRM INTERNATIONAL SENIOR SECONDARY SCHOOL (CBSE)

S.F.No. 970/1Apart, Tekkattur Village,

Arimalam Panchayat Union, Thirumayam Taluk, Pudukkottai District.

This Report does not include any eventualities caused due to natural calamities.

We hereby advise that periodical repairs and renovations shall be carried out to the Entire building Blocks regularly by every year and intimating me thro writing.

Further necessary fire fighting equipments should be kept in the premises and should be Trained for operation. If any fire accident/mishap occurs we are not held responsible.

Structural alteration/deviation should not be carried out to a part of whole building Without prior permission from the Panel Engineer..


Emergency exit to be provided as per norms.

All electrical points, wiring/Gadgets has to be checked properly and to be maintained Periodically- this competent Engineer is not held responsible for electrical defaults.

If any violation is found at a later stage after issue of this report we are not held Responsible and this report gets cancelled.

Further this report covers the certified blocks & floors only-Legal aspects are not Considered. Technical soundness only considered.

Date : 20.09.2020



Signature of the inspecting authority

A. BALASUBRAMANIAN, B.E., M.I.E.,
CHARTERED ENGINEER & PANEL ENGINEER GRADE - 1A
PUDUKKOTTAI DISTRICT
49, Muneeswaran Koil Street,
KARAIKUDI - 630 001. Mob : 9442237183